



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

August 17, 2011

ARJOHUNTLEIGH
GARY LOFGREN
50 N GARY AVE SUITE A
ROSELLE IL 60172

ARJOHUNTLEIGH HOSPITAL EQUIPMENT AB
JOHN WENNBORG
PO BOX 61
ESLOV
SWEDEN

Re: Description: HEALTH CARE PLUMBING APPLIANCE
Manufacturer: ARJOHUNTLEIGH HOSPITAL EQUIPMENT AB
Product Name: SHOWER PANEL
Model Number(s): BCA1204-04 or BCA1214-04
Product File No: 20110258

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2016.

This approval is contingent upon compliance with the following stipulation(s):

- This plumbing product must be installed with the critical level of the vacuum breaker not less than six inches above the highest use of the hose tip of this product.

This approval supersedes the approval issued on October 26, 2006 under product file number 20060887.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060887.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov